

# P6-700.3F CUSTOM REMOTE ANNUNCIATOR

**National Electrical Code 2017 Provision 700.3(F)**

A remote annunciator or alarm panel is required to give an audible and visual annunciation that the permanent emergency source is disconnected from the emergency system.

**TEXT**

THE PERMANENT EMERGENCY SOURCE IS DISCONNECTED FROM THE EMERGENCY SYSTEM

FEATURES	
#	DESCRIPTION
1	NEMA1 8"x10"x4" METAL ENCLOSURE
2	TITLE
3	22mm LED
4	1/8" BLACK ENGRAVABLE PLASTIC FACEPLATE, WALL MOUNT
5	ANNUNCIATION TEXT
6	THREE POSITION MOMENTARY "LAMP TEST/ALARM SILENCE" TOGGLE SWITCH
7	COMPANY NAME & PHONE
8	ALARM HORN 90 DB AT 12 OR 24 VDC

<small>UNLESS OTHERWISE SPECIFIED:</small> ALL DIMENSIONS INCHES DO NOT SCALE DRAWING PURCHASE ORDER: XXXXXXXXX	 Engine & Generator Controls <b>P6</b> EMS DISCONNECT INDICATION SAMPLE LAYOUT	DRAWN BY: TE CHECKED: Lxxx SCALE: NONE DATE: 03/04/20 DRAWING NUMBER: Lxxx SHEET 1 OF 1
--	--	--

## STANDARD FEATURES

- Custom Engraved 3-Ply Plastic
- Single 22 mm Red LED
- Visual & Audible Indication
- Alarm Silence / Lamp Test Switch
- Input Selectable Horn
- Surface Mount
- NEMA 1 8" X 10" X 4" Enclosure
- DC Positive Input Switching
- 12 or 24 Volts DC
- Fully Sealed Logic Module

## OPTIONAL

- Flush Mount
- Inverter for DC Negative Inputs